

DRILLER'S COPY LIC

WELL PERMIT NUMBER	237999	RECEIVED
DIV. 5	WD 70	DES. BASIN MD
APR 08 2002		

APPLICANT

MARLION W & JUDY D HOLT  
13890 COUNTY ROAD 204  
DEBEQUE, CO 81630-

(970) 283-9216

APPROVED WELL LOCATION  
GARFIELD COUNTY, COLO.  
SW 1/4 SE 1/4 Section 25  
Township 6 S Range 99 W Sixth P.M.

DISTANCES FROM SECTION LINES  
250 Ft. from South Section Line  
2636 Ft. from East Section Line

UTM COORDINATES  
Northing: Easting:

PERMIT TO CONSTRUCT A WELL

ISSUANCE OF THIS PERMIT DOES NOT CONFER A WATER RIGHT  
CONDITIONS OF APPROVAL

- 1) This well shall be used in such a way as to cause no material injury to existing water rights. The issuance of this permit does not assure the applicant that no injury will occur to another vested water right or preclude another owner of a vested water right from seeking relief in a civil court action.
- 2) The construction of this well shall be in compliance with the Water Well Construction Rules 2 CCR 402-2, unless approval of a variance has been granted by the State Board of Examiners of Water Well Construction and Pump Installation Contractors in accordance with Rule 18.
- 3) Approved pursuant to CRS 37-92-602(3)(b)(II)(A) as the only well on a tract of land of 91.80 acres described as that portion of the SW 1/4, SE 1/4, Sec. 25, Twp. 6 S, Rng. 99 W, Sixth P.M., Garfield County, more particularly described on the attached exhibit A.
- 4) The use of ground water from this well is limited to fire protection, ordinary household purposes inside not more than three (3) single family dwellings, the irrigation of not more than one (1) acre of home gardens and lawns, and the watering of domestic animals.
- 5) The maximum pumping rate of this well shall not exceed 15 GPM.
- 6) The return flow from the use of this well must be through an individual waste water disposal system of the non-evaporative type where the water is returned to the same stream system in which the well is located.
- 7) This well shall be constructed not more than 200 feet from the location specified on this permit.

NOTE: Parcel Identification Number (PIN): 23-2165-253-00-007  
NOTE: Assessor Tax Schedule Number: 290093

SAB  
12.13.2001

APPROVED  
SAP

*Hel A. Simon*  
State Engineer

*Steve A. Bign*  
By

Receipt No. 9500891

DATE ISSUED DEC 13 2001

EXPIRATION DATE DEC 13 2003